



**Foundation Systems**

818 SW 142nd, Seattle, WA 98166

(206) 244-1023 fax (206) 241-9101

www.robbinsfoundationsystems.com

client: [Redacted]

Certified Installer:  
**Robbie Grondahl**

Date:  
**5/16/2011**

address:  
**Copalis Beach, WA 98535**

Weather:  
**Sunny**

Pier Numbers:  
**1 to 9**

### Grip-Tite® Push Pier Pressure Log

Test Pier #7		
Tube	Depth (ft)	Gage (psi)
1	1.5	600
1	3	800
2	4.5	800
2	6	1000
3	7.5	1200
3	9	1600
4	10.5	2000
4	12	2200
5	13.5	2600
5	15	3000
6	16.6	3600
6		
7		
7		
8		
8		
9		
9		
10		
10		
11		
11		
12		
12		
13		
13		
14		
14		
15		
15		
16		
16		
18		
18		

All Piers				
#	Depth (ft)	Gage (psi)	Area	Force
1	10	3500	9.62	33670
2	10	3500	9.62	33670
3	18	3600	9.62	34632
4	16	3600	9.62	34632
5	16.6	3600	9.62	34632
6	17	3500	9.62	33670
7	16.6	3600	9.62	34632
8	16	3600	9.62	34632
9	16	3600	9.62	34632

