



Foundation Systems

818 SW 142nd, Seattle, WA 98166

(206) 244-1023 fax (206) 241-9101

www.robbinsfoundationsystems.com

client:
 [Redacted]

Certified Installer:
 Robbie Grondahl

Date:
 5/23/2011

address:
 Auburn, WA 98002

Weather:
 Sunny

Pier Numbers:
 1 to 10

Grip-Tite® Push Pier Pressure Log

Test Pier # 6		
Tube	Depth (ft)	Gage (psi)
1	1.5	400
1	3	500
2	4.5	600
2	6	600
3	7.5	1400
3	9	900
4	10	3400
4		
5		
5		
6		
6		
7		
7		
8		
8		
9		
9		
10		
10		
11		
11		
12		
12		
13		
13		
14		
14		
15		
15		
16		
16		
18		
18		

All Piers				
#	Depth (ft)	Gage (psi)	Area	Force
1	10	2600	9.62	25012
2	10.8	2600	9.62	25012
3	11	2600	9.62	25012
4	11	2600	9.62	25012
5	10	2800	9.62	26936
6	10	3400	9.62	32708
7	10.8	2800	9.62	26936
8	10.6	2600	9.62	25012
9	11	2600	9.62	25012
10	11	2600	9.62	25012

