



Foundation Systems

818 SW 142nd, Seattle, WA 98166
 (206) 244-1023 fax (206) 241-9101
 www.robbinsfoundationsystems.com

client: [Redacted]
 address: [Redacted]
 Puyallup, WA 98372

Certified Installer:
Leon Kellogg
 Weather:
Sunny

Date:
5/24/2011
 Pier Numbers:
1 to 6

Grip-Tite® Push Pier Pressure Log

Test Pier #3		
Tube	Depth (ft)	Gage (psi)
1	1.5	300
1	3	0
2	4.5	1200
2	6	400
3	7.5	800
3	9	1200
4	10.5	1500
4	12	1500
5	13.6	3500
5		
6		
6		
7		
7		
8		
8		
9		
9		
10		
10		
11		
11		
12		
12		
13		
13		
14		
14		
15		
15		
16		
16		
18		
18		

All Piers				
#	Depth (ft)	Gage (psi)	Area	Force
1	12.1	3200	9.62	30784
2	13	3300	9.62	31746
3	13.6	3500	9.62	33670
4	13.2	3500	9.62	33670
5	13.8	3500	9.62	33670
6	13.2	3500	9.62	33670

